## MAR 1 9 1992

5HSGI ESS SPCC 0H9212059G

Mr. William E. Lacure Senior Environmental Control Analyst The Timken Company, GNE-02 1835 Dueber Avenue Canton, Ohio 44706



Dear Mr. Lacure:

A recent inspection of that portion of your facility known as the Canton Bearing Plant indicates that your Spill Prevention, Control and Countermeasure (SPCC) Plan conforms to the requirements of the Code of Federal Regulations, Title 40, Part 112. The Harrison Steel Division, the Faircrest Steel Division and the Gambrinus Bearing Plant SPCC Plans will be addressed under seperate cover on an individual basis. We appreciate your concern for a healthy environment.

We would like to take this opportunity to remind you that your SPCC Plan should be reviewed every 3 years. Should any physical changes be made in your oil storage facilities, your SPCC Plan should be updated and signed by a registered professional engineer. We would also appreciate being kept informed of any voluntary changes made to your facility that will improve spill prevention.

If a spill should occur, the Clean Water Act, Section 311(b)(5), requires that it be reported to the Federal Government. This may be done by contacting the National Response Center at 800-424-8802.

If you have any questions, please feel free to contact me or Ms. Kathleen F. Power of my staff at (313) 692-7666.

Sincerely,

Pamela J. Schafer, Chief Emergency Support Section

5HSGI: POWER: tlc: 12/17/91: A:TIMKIN.001

FORM 1 - IN COMPLIANCE